



September 21, 2013

Ms. Grissel V. Diaz-Cotto
Emergency and Remedial Response Division
United States Environmental Protection Agency
Region II
290 Broadway, 19th Floor
New York, NY 10007-1866

**Re: August 2013 Discharge Monitoring Report
Leachate Treatment Plant, Operable Unit 1
Kin-Buc Landfill Superfund Site**

Dear Ms. Diaz-Cotto:


Please find enclosed the August 2013 Discharge Monitoring Report (DMR) for the Leachate Treatment Plant of Operable Unit One at the Kin-Buc Landfill Superfund Site.

Weston & Sampson Services, Inc. would like to confirm the following:

- Effluent parameters sampled throughout month were within permitted limits.

Should you have any questions concerning this DMR or the Treatment Plant, please contact me at your earliest convenience at the Kin-Buc site.

Very truly yours,
Weston & Sampson Services, Inc. on behalf of SCA Services, Inc.


Glenn Grieb
Plant Manager
Enclosure

**Cc: Martha Goodwin – NJDEP
Stephen Joyce – SC Holdings, Inc.
Carl Januszkiewicz – SC Holdings, Inc.
John A. Bocchino, Jr. – Weston & Sampson Services, Inc.**

294323



Connecticut 273 Dividend Road Rocky Hill, CT 06067	Rhode Island 477B Tiogue Avenue Coventry, RI 02816	New Hampshire 100 International Drive Suite 152 Portsmouth, NH 03801	Maine PO Box 189 York, ME 03909	Vermont 96 South Main Street Suite 2 Waterbury, VT 05676	New York 301 Manchester Road Suite 201A Poughkeepsie, NY 12603	Florida 1990 Main Street Suite 750 Sarasota, FL 34236
---	---	--	--	--	--	---

When it's essential...it's Weston&Sampson.®

NEW JERSEY DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF WATER QUALITY

MONITORING REPORT - TRANSMITTAL SHEET

NJPDDES NO.
*NJ Permit Equivalent

*					
---	--	--	--	--	--

REPORTING PERIOD

M	o.	Y	r.	M	o.	Y	r.
0	8	1	3	0	8	1	3

PERMITTEE: Name: SCA Services, Inc.
Address: 383 Meadow Road
Edison, New Jersey 08817

FACILITY: Name: Kin-Buc Landfill
Address: 383 Meadow Road
Edison, New Jersey 08817
Telephone: 732-572-4743

FORMS ATTACHED (Indicate Quantity of Each)

Operating Exceptions

SLUDGE REPORT-SANITARY
__ T-VWX-007 __ T-VWX-008 __ T-VWX-009
__ EPA Form 3320-1

DYE TESTING YES NO
__ X

SLUDGE REPORT-INDUSTRIAL
__ T-VWX-010A __ T-VWX-010B

TEMPORARY BYPASSING __ X

DISINFECTION INTERRUPTION __ X

WASTEWATER REPORTS
__ T-VWX-011 __ T-VWX-012 __ T-VWX-013

MONITORING MALFUNCTIONS __ X

UNITS OF OPERATION __ X

GROUNDWATER REPORTS
__ T-VWX-015(A,B) __ T-VWX-016 __ T-VWX-017
__ ELECTRONIC SUBMISSION

OTHER __ X

NPDES DISCHARGE MONITORING
1 EPA Form 3320-1


(Detail any "Yes" on reverse side in appropriate space.)


NOTE: The "Hours Attended at Plant" on the reverse of this sheet must also be completed.

AUTHENTICATION I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

LICENSED OPERATOR

**PRINCIPAL EXECUTIVE OFFICER OR
DULY AUTHORIZED REPRESENTATIVE**

Name (Printed) Glenn Grieb
Grade & Registry No. N-4 ; 0021212
Signature 

Name (Printed) Glenn Grieb
Title (Printed) Plant Operations Manager
Signature 

Date September 18, 2013

This image shows a single sheet of white paper with horizontal ruling lines. The lines are evenly spaced and run across the width of the page. There are no margins, text, or other markings on the paper.

MONTH

0	8
---	---

YEAR

1	3
---	---

Others

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
8	8	4	0	8	9	8	8	8	4	4	8	6	8	8	7
22	16	0	0	16	16	24	16	8	0	4	8	8	8	16	8
17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
0	2	8	8	5	2	8	0	0	8	8	8	8	8	8	
0	0	8	16	16	16	8	4	4	8	16	16	20	14	8	

PERMITTEE NAME/ADDRESS

NAME

ADDRESS

SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

FACILITY

LOCATION

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT			001		
PERMIT NUMBER			DISCHARGE NUMBER		
MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
13	08	01	13	08	31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.022903	0.036067	MGD	*****	*****	*****	***	***	continuous	flow meter
	PERMIT REQUIREMENT	REPORT	ONLY		*****	*****	*****			continuous	flow meter
pH	SAMPLE MEASUREMENT	*****	*****	***	8.10	*****	8.48	S.U.	0	1/week	grab
	PERMIT REQUIREMENT	*****	*****		6.0	*****	9.0			weekly	grab
PETROLEUM HYDROCARBONS	SAMPLE MEASUREMENT	*****	*****	***	*****	0.47	0.5	mg/l	0	2/month	grab
	PERMIT REQUIREMENT	*****	*****		*****	10	15			2/month	grab
COD	SAMPLE MEASUREMENT	19.25	20.01	kg/day	*****	172	175	mg/l	0	2/month	comp.
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT	ONLY			2/month	comp.
BOD	SAMPLE MEASUREMENT	*****	*****	***	*****	1.7	1.7	mg/l	0	2/month	comp.
	PERMIT REQUIREMENT	*****	*****		*****	55	220			2/month	comp.
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT	0.37	0.50	kg/day	*****	3.35	4.80	mg/l	0	1/week	comp.
	PERMIT REQUIREMENT	REPORT	ONLY		*****	30	45(1)			weekly	comp.
DISSOLVED OXYGEN	SAMPLE MEASUREMENT	*****	*****	***	5.61	*****	*****	mg/l	0	1/week	grab
	PERMIT REQUIREMENT	*****	*****		4.0 MIN Instantaneous	*****	*****			weekly	grab
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and I am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years)				TELEPHONE		DATE			
Glenn Grieb Project Manager						732 572-4743		13 09 18			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT				AREA CODE		NUMBER		YEAR MO DAY	
COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS		(REFERENCE ALL ATTACHMENTS HERE)									

PERMITTEE NAME/ADDRESS
NAME
ADDRESS


FACILITY
LOCATION
ATTN:

SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT PERMIT NUMBER			001 DISCHARGE NUMBER		
MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
13	08	01	13	08	31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BENZENE	SAMPLE MEASUREMENT	<0.0000127	<0.0000159	kg/day	*****	0.12	0.15	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.009	0.02		*****	57	134			2/month	grab
CHLOROBENZENE	SAMPLE MEASUREMENT	<0.0000124	<0.0000131	kg/day	*****	<0.11	<0.11	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.022	0.058		*****	142	380			2/month	grab
1,1 DICHLOROETHENE	SAMPLE MEASUREMENT	<0.0000146	<0.0000154	kg/day	*****	<0.13	<0.13	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.003	0.009		*****	22	59			2/month	grab
ETHYLBENZENE	SAMPLE MEASUREMENT	<0.0000112	<0.0000119	kg/day	*****	<0.10	<0.10	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.022	0.058		*****	142	380			2/month	grab
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT	<0.0000112	<0.0000119	kg/day	*****	<0.10	<0.10	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.008	0.025		*****	52	184			2/month	grab
TOLUENE	SAMPLE MEASUREMENT	0.0000179	0.0000180	kg/day	*****	0.16	0.17	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.004	0.011		*****	28	74			2/month	grab
1,2-TRANSDICHLOROETHYLENE	SAMPLE MEASUREMENT	<0.0000146	<0.0000154	kg/day	*****	<0.13	<0.13	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.004	0.009		*****	25	60			2/month	grab
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and I am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)						TELEPHONE		DATE	
Glenn Grieb Project Manager								732 572-4743		13 09 18	
TYPED OR PRINTED								AREA CODE NUMBER		YEAR MO DAY	
COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS		(REFERENCE ALL ATTACHMENTS HERE)				SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					

PERMITTEE NAME/ADDRESS
NAME
ADDRESS
FACILITY
LOCATION
ATTN:


SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT		001	
PERMIT NUMBER		DISCHARGE NUMBER	
MONITORING PERIOD			
YEAR	MO	DAY	TO
13	08	01	13 08 31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TRICHLOROETHYLENE	SAMPLE MEASUREMENT	<0.0000101	<0.0000107	kg/day	*****	<0.09	<0.09	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.004	0.010		*****	28	69			2/month	grab
VINYL CHLORIDE	SAMPLE MEASUREMENT	<0.0000156	<0.0000183	kg/day	*****	<0.14	<0.14	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	0.008	0.016		*****	52.8	106			weekly	grab
ACENAPHTHYLENE	SAMPLE MEASUREMENT	<0.0000040	<0.0000043	kg/day	*****	<0.036	<0.036	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
BENZO(A)ANTHRACENE	SAMPLE MEASUREMENT	<0.0000051	<0.0000055	kg/day	*****	<0.05	<0.05	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
BENZO(A)PYRENE	SAMPLE MEASUREMENT	<0.0000068	<0.0000072	kg/day	*****	<0.061	<0.061	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
BENZO(ghi)PERYLENE	SAMPLE MEASUREMENT	<0.0000118	<0.0000131	kg/day	*****	<0.105	<0.110	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
BENZO(k)FLUORANTHENE	SAMPLE MEASUREMENT	<0.0000049	<0.0000052	kg/day	*****	<0.044	<0.044	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	<div>I certify under penalty of law that I have personally examined and I am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)</div> <div>(REFERENCE ALL ATTACHMENTS HERE)</div> <div><0.00017</div>	<div></div> <div>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</div>	TELEPHONE	DATE	
Glenn Grieb Project Manager			732 572-4743	13 09 18	
TYPED OR PRINTED	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS

PERMITTEE NAME/ADDRESS
NAME
ADDRESS

SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

FACILITY
LOCATION
ATTN:

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT			001		
PERMIT NUMBER			DISCHARGE NUMBER		
MONITORING PERIOD					
YEAR	MO	DAY	TO		YEAR
13	08	01			13
					08
					31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IDENO(1,2,3cd) PYRENE	SAMPLE MEASUREMENT	<0.0000219	<0.0000238	kg/day	*****	<0.195	<0.200	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
PHENANTHRENE	SAMPLE MEASUREMENT	<0.0001790	<0.0004172	kg/day	*****	<1.612	<3.2	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	5.4(2)			weekly	grab
ALDRIN	SAMPLE MEASUREMENT	<0.0000019	<0.0000020	kg/day	*****	<0.017	<0.017	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.000133	0.00026		*****	0.0875	0.176			monthly	grab
4,4-DDT	SAMPLE MEASUREMENT	<0.0000030	<0.0000035	kg/day	*****	<0.027	<0.027	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	0.0000578	0.000146		*****	0.38	0.766			weekly	grab
PCB-1242	SAMPLE MEASUREMENT	<0.0000087	<0.0000103	kg/day	*****	<0.08	<0.08	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab
PCB-1248	SAMPLE MEASUREMENT	<0.0000087	<0.0000103	kg/day	*****	<0.08	<0.08	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab
PCB-1254	SAMPLE MEASUREMENT	<0.0000084	<0.0000100	kg/day	*****	<0.08	<0.08	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and I am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)					TELEPHONE		DATE		
Glenn Grieb Project Manager							732 572-4743		13 09 18		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS

(REFERENCE ALL ATTACHMENTS HERE)

PERMITTEE NAME/ADDRESS
NAME
ADDRESS


SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

FACILITY
LOCATION
ATTN:

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT			001			
PERMIT NUMBER			DISCHARGE NUMBER			
MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
13	08	01		13	08	31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PCB-1260	SAMPLE MEASUREMENT	<0.0000084	<0.0000100	kg/day	*****	<0.08	<0.08	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab
ARSENIC	SAMPLE MEASUREMENT	0.0006803	0.0007562	kg/day	*****	6.20	7.20	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.013	0.026		*****	85.8	172			weekly	comp
CADMIUM	SAMPLE MEASUREMENT	<0.0002119	<0.0002477	kg/day	*****	1.9	1.9	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.0073	0.017		*****	48.2	112			weekly	comp
CHROMIUM	SAMPLE MEASUREMENT	0.0004461	0.0005216	kg/day	*****	4.00	4.00	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.030	0.060		*****	198	396			weekly	comp
COPPER	SAMPLE MEASUREMENT	0.0004108	0.0005616	kg/day	*****	3.8	5.3	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	10			weekly	comp
LEAD	SAMPLE MEASUREMENT	0.0001338	0.0001565	kg/day	*****	1.20	1.20	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	10			weekly	comp
NICKEL	SAMPLE MEASUREMENT	0.0035482	0.0042246	kg/day	*****	31.9	32.9	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.140	0.281		*****	124	1850			weekly	comp
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and I am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years)						TELEPHONE		DATE	
Glenn Grieb Project Manager								732 572-4743		13 09 18	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT				AREA CODE		NUMBER		YEAR MO DAY	
COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS		(REFERENCE ALL ATTACHMENTS HERE)									

PERMITTEE NAME/ADDRESS
NAME
ADDRESS

SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

FACILITY
LOCATION
ATTN:

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT			001			
PERMIT NUMBER			DISCHARGE NUMBER			
MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
13	08	01		13	08	31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
ZINC	SAMPLE MEASUREMENT	0.0017062	0.0019949	kg/day	*****	15.3	15.3	ug/L	0	1/week	comp	
	PERMIT REQUIREMENT	0.177	0.358		*****	1170	2350			weekly	comp	
CYANIDE	SAMPLE MEASUREMENT	<0.0004461	<0.0005216	kg/day	*****	4.0	4.0	ug/L	0	1/week	comp	
	PERMIT REQUIREMENT	0.002	0.004		*****	12.2	26.4			weekly	comp	
ALUMINUM	SAMPLE MEASUREMENT	0.0168292	0.0272308	kg/day	*****	148.3	257.0	ug/L	0	1/week	comp	
	PERMIT REQUIREMENT	1.40	2.81		*****	9240	18500			weekly	comp	
IRON	SAMPLE MEASUREMENT	0.0143858	0.0168200	kg/day	*****	129.0	129.0	ug/L	0	1/week	comp	
	PERMIT REQUIREMENT	80.6	162		*****	532000	1070000			weekly	comp	
ACUTE TOXICITY, (LC50)	SAMPLE MEASUREMENT	QUARTELY	REPORT	***	n/a	*****	*****	%	0			
	PERMIT REQUIREMENT	*****	*****		50(3)	*****	*****			see permit	equivalent	
Ammonia	SAMPLE MEASUREMENT	*****	*****	***	*****	0.290	0.300	mg/l	0	*****	*****	
	PERMIT REQUIREMENT	*****	*****		*****	4.9	10.0			2/month	comp	
	SAMPLE MEASUREMENT	*****	*****	***	*****	*****	*****	***	***	*****	*****	
	PERMIT REQUIREMENT	*****	*****		*****	*****	*****			*****	*****	
NAME/TITLE: PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years)				SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TELEPHONE		DATE		
Glenn Grieb Project Manager								732	572-4743	13	09	18
TYPED OR PRINTED						AREA CODE		NUMBER		YEAR	MO	DAY
COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS		REFERENCE ALL ATTACHMENTS HERE)										